



NOTES:

1. 1"-8" METERS SHALL BE INSTALLED HORIZONTAL WITH A MINIMUM OF 24" CLEARANCE LEFT AND RIGHT FROM OTHER STRUCTURES OR EQUIPMENT. THERE SHALL BE A MINIMUM OF 36" CLEARANCE FROM THE FOUNDATION WALL FOR INSPECTION, REPLACEMENT, OR REPAIR.
2. SEE PLUMBING DIAGRAM FOR FLOOR DRAIN LOCATION.

COMMERCIAL/BUSINESS WATER SUPPLY ARRANGEMENT DETAIL



DATE	REVISIONS
1-9-19	Moved Fire Suppression
4-1-21	Added Plan Notes & Details
5-1-23	Added Note
2-17-25	Revised Detail

STANDARD DETAIL
W-10 (04)