



NOTES:

- 1"–2" METERS SHALL BE INSTALLED HORIZONTAL WITH A MINIMUM OF 24" CLEARANCE LEFT AND RIGHT FROM OTHER STRUCTURES OR EQUIPMENT. THERE SHALL BE A MINIMUM OF 36" CLEARANCE FROM THE FOUNDATION WALL FOR INSPECTION, REPLACEMENT, OR REPAIR.
2. CRAWLSPACE AND PIT-SET METER INSTALLATION SHALL ONLY BE ALLOWED BY WRITTEN AUTHORIZATION FROM THE DIRECTOR OF PUBLIC WORKS OR DESIGNEE.
3. A STOPCOCK OR VALVE SHALL BE PLACED ON EACH SIDE OF THE METER. NO OTHER CONNECTIONS OR VALVES ARE ALLOWED BEFORE THE METER WITH THE EXCEPTION OF THE FIRE SUPPRESSION SYSTEM CONNECTION. ONLY FULL PORT BALL OR GATE VALVES SHALL BE USED. THE DRAIN SHALL BE LOCATED BETWEEN THE WATER METER AND VALVE 3.

SINGLE FAMILY/MULTI-FAMILY WATER SUPPLY ARRANGEMENT DETAIL

DATE	REVISIONS
1-9-19	Added Drain Valve
4-1-21	Added Plan Notes & Details
5-1-23	Revised Detail
2-17-25	Revised Detail