



NOTES:

1. INSULATION BOARD TO BE CLOSED CELL, EXTRUDED POLYSTYRENE FOAM MEETING ASTM 578, TYPE VI, 40 PSI COMPRESSIVE STRENGTH (ASTM D-1621) 0.1% MAX. WATER ABSORPTION (ASTM C-272).
2. BACKFILL MATERIAL AROUND INSULATION MUST BE FINE SAND FREE FROM ROOTS, ORGANIC MATTER OR OTHER DAMAGING MATERIALS.
3. OVERLAP ALL INSULATION BOARD JOINTS.

WATER MAIN TRENCH INSULATION DETAIL