



NOTES:

1. ALL BELOW GRADE FASTENERS TO BE STAINLESS STEEL:
 - A. BOLTS & THREADED RODS - GRADE #304
 - B. NUTS & WASHERS - GRADE #316
2. VALVES 12" OR LARGER MAY REQUIRE OFFSET CONES.
3. ALL WATER SHALL BE REMOVED FROM VAULT PRIOR TO FINAL PROJECT INSPECTION
4. VALVE VAULT SIZE SHALL CORRESPOND TO THE TYPE AND SIZE OF VALVE AS FOLLOWS:
 - A. 8" VALVE OR SMALLER = 48" VALVE VAULT
 - B. 10"-16" VALVE & PRESSURE CONNECTIONS = 60" DIA. VALVE VAULT
 - C. 18" VALVE OR LARGER & VALVES W/AIR RELEASE = 72" DIA. VALVE VAULT

WATER MAIN VALVE VAULT DETAIL



DATE

1-9-19 Revised Notes

5-1-23 Revised Callouts

REVISIONS

STANDARD DETAIL
W-3 (02)