



NOTES:

1. WATER SERVICE TAPS ON VILLAGE OWNED WATER MAIN MUST BE MADE THROUGH A TAPPING DEVICE AS SPECIFIED ABOVE UNLESS OTHERWISE DIRECTED BY VILLAGE STAFF.
2. ALL TREE ROOTS CONFLICTING WITH THE PROPOSED WATER SERVICE INSTALLATION MUST BE ROOT PRUNED WITH A VERMEER V2050, OR APPROVED EQUAL "WALK BEHIND" ROOT PRUNING MACHINE TO A MINIMUM DEPTH OF 16 INCHES PRIOR TO ANY EXCAVATION. THE WATER SERVICE MUST BE RELOCATED ACCORDINGLY IF STAFF DETERMINES THAT EXCAVATION WILL THREATEN THE HEALTH OF EXISTING TREES.
3. REFER TO STANDARD W-15 FOR TRACER WIRE DETAIL FOR PVC WATER MAIN
4. CONTRACTOR IS TO SCHEDULE AN INSPECTION FOR EACH SERVICE CONNECTION WITH RESIDENT ENGINEER PRIOR TO BACKFILLING
5. BACKFILL TO BE PLACED IN 8" LOOSE LIFTS AND COMPACTED WITH A MECHANICAL COMPACTOR AND IS SUBJECT TO THE APPROVAL OF THE VILLAGE ENGINEER
6. IF BUFFALO BOX IS LOCATED WITHIN DRIVEWAY OR APRON, AN AUXILIARY VALVE BOX TOP WITH "WATER" LID IS REQUIRED

## WATER SERVICE DETAIL