



NOTES:

1. CABLE DUCT SHALL BE A MINIMUM OF 2' TO A MAXIMUM OF 3' BEHIND THE BACK OF CURB.
2. ALL SURFACES MUST BE RESTORED TO THEIR ORIGINAL CONDITION.
3. WIRING SHALL BE THERMOPLASTIC, HIGH HEAT AND WATER RESISTANT TYPE (THW) AS LISTED IN THE NEC CURRENTLY ADOPTED BY V.O.N.
4. DUCT TO BE 1.5" SCHEDULE 40 OR 80:  
SCHEDULE 40 WITHIN PARKING LOT  
SCHEDULE 80 EXTERIOR OF PARKING LOT

## BURIED CABLE TRENCH DETAIL



**northbrook**  
Public Works Department

DATE	REVISIONS
4-30-20	Revised Notes & Specifications
5-1-23	Revised Notes

**STANDARD DETAIL  
R-5 (02)**