



NOTES:

- 1) TRENCH BACKFILL FOR PAVED AREAS, INCLUDING ROAD, CURB AND SIDEWALK:
CONTROLLED LOW STRENGTH MATERIAL (CLSM). (CA-6 OR APPROVED EQUAL MAY BE USED ONLY WHEN APPROVED BY THE VILLAGE ENGINEER) TBF REQUIRED 2 FEET BEYOND ANY PAVED SURFACE
- 2) TRENCH BACKFILL FOR NON-PAVED AREAS:
FINELY DIVIDED EXCAVATED MATERIAL FREE FROM ROCKS AND DEBRIS
- 3) RISER REQUIRED WHEN SEWER DEPTH EXCEEDS NINE (9) FEET. MAXIMUM SLOPE OF 1:1 ON RISERS
- 4) INSTALL DIP SERVICE LINE FROM FOUNDATION WALL TO THE OUTSIDE OF BUILDING OVERDIG, OR 10 L.F. MIN. AND INSTALL CLEAN-OUT AT THIS LOCATION
- 5) NEW CONNECTIONS TO MAIN SHALL BE INSTALLED WITH ROMAC CB OR FORD FSS SEWER SADDLE OR VILLAGE ENGINEER APPROVED EQUAL
- 6) USE LMT(tm) STYLE SADDLE SYSTEM INSTALLATION OR PRE-APPROVED EQUIVALENT WHEN TAPPING LINED SANITARY MAIN. REMOVE HOST CLAY PIPE AS NECESSARY
- 7) P.V.C., SDR26 SHALL BE USED EXCEPT FOR WHEN WATER MAIN QUALITY PIPE IS REQUIRED. IN THAT CASE USE GREEN C-900 P.V.C PIPE
- 8) SANITARY SERVICES ARE NOT PERMITTED IN RESIDENTIAL SIDE YARDS

SEWER SERVICE DETAIL



DATE	REVISIONS
4-30-20	Revised Notes
5-12-22	Controlled Low Strength Material

STANDARD DETAIL
SS-3 (02)